


DWG NO. C1

DWG NO. C2

DWG NO. C3

LEGEND

- GENERAL EXTENTS OF PLAN AND PROFILE SHEETS (DWG NO. C1- DWG NO. C5)
- PIPE ALIGNMENT
- SECTION LINE
- APPROXIMATE PROPERTY LINE
- CENTER LINE
- RIGHT OF WAY LINE




DEDICATED RIGHT OF WAY (R/W)

HATCH PATTERN: ANS131
SCALE: .50 OF DRAWING SCALE
ANGLE: 0°



SBMWD EASEMENT

HATCH PATTERN: ANS136
SCALE: .375 x DRAWING SCALE
ANGLE: 285°



TEMPORARY EASEMENT

HATCH PATTERN: BRASS
SCALE: .375 x DRAWING SCALE
ANGLE: 30°

ABBREVIATIONS

US = UNITED STATES OF AMERICA
GLO = GENERAL LAND OFFICE
DEP RSVY = DEPENDENT RESURVEY
BLM = BUREAU OF LAND MANAGEMENT

DESCRIPTIONS

BOOK AND PAGE = SAN BERNARDINO COUNTY RECORDER'S OFFICE
BOOK AND INSTRUMENT = SAN BERNARDINO COUNTY RECORDER'S OFFICE

ASSESSOR PARCEL NUMBERS

APN- BBBB- EEE- PPP

INDIVIDUAL PARCEL NUMBER
ASSESSOR'S PAGE BLOCK NUMBER
ASSESSOR'S BOOK NUMBER
ASSESSOR'S PARCEL NUMBER

SURVEY MONUMENTATION NOTES:

- CONTRACTOR SHALL ESTABLISH SUFFICIENT MONUMENTS SO THAT A MINIMUM OF THREE HORIZONTAL AND VERTICAL CONTROL MONUMENTS EXIST FOR EACH PROJECT. ALL MONUMENTS SHALL BE DURABLE, PERMANENT MONUMENTS WITH SBMWD MARKINGS. MONUMENT SHALL BE CONCRETE MONUMENT WITH BRASS DISK AS SHOWN ON STANDARD DRAWING NO. W6.2. WHEN BRASS DISK MONUMENT IS NOT APPLICABLE, OTHER ACCEPTABLE MONUMENTS WOULD INCLUDE:
2-INCH GALVANIZED STEEL PIPE 30-INCHES LONG; WITH BRASS DISK OR PLASTIC PLUG
5/8" DIAMETER REBAR, 30-INCHES LONG WITH CAP
BRASS DISK EPOXIED IN ROCK MASS OR BRIDGE ABUTMENT
ANY EXISTING STABLE MONUMENTS
- CONTRACTOR SHALL SET HORIZONTAL CONTROL MONUMENTS AS REQUIRED BY PROJECT CONDITIONS, NO MORE THAN 1/2 MILE APART. IF LONGER SPACING IS USED, ESTABLISH MONUMENTS IN PAIRS FOR INTERVISIBILITY. MINIMUM SPACING FOR MONUMENTS IS 500 FEET (1,000 FEET WHEN USING GPS).
- MONUMENTS SHALL BE ACCESSIBLY LOCATED, WITHIN PUBLIC RIGHT-OF-WAY OR EASEMENT, TO MINIMIZE DISTURBANCE BY CONSTRUCTION AND BE CLEAR OF TRAFFIC.
- HORIZONTAL CONTROL MONUMENTS SHALL BE SET SO THEY ARE INTER VISIBLE WITH A MINIMUM OF TWO OTHER MONUMENTS.
- CONTRACTOR SHALL SET VERTICAL CONTROL MONUMENTS AS REQUIRED BY PROJECT CONDITIONS, NO MORE THAN 1/2 MILE APART. CONTRACTOR SHALL UTILIZE HORIZONTAL CONTROL MONUMENTS AS VERTICAL CONTROL MONUMENTS, WHENEVER POSSIBLE.
- CONTRACTOR SHALL SET VERTICAL CONTROL MONUMENT AT EACH MAJOR STRUCTURE, WHENEVER POSSIBLE.

NOTE:
1"=200' SCALE (MAX) PERMITTED ONLY, MORE THAN ONE SHEET MAY BE REQUIRED.

DWG NO. C4

DWG NO. C5



UNDERGROUND SERVICE ALERT
CALL: TOLL FREE
811
TWO WORKING DAYS BEFORE YOU DIG

INSERT ENGINEER'S STAMP HERE
ENGINEER'S SEAL

INSERT CONSULTANT LOGO, NAME, ADDRESS AND PHONE NO. HERE

APPROVED BY: _____ DATE: _____
REGISTERED CIVIL ENGINEER No. XXXXX

MARK	REVISIONS	APPROVED	DATE	APPROVED	DATE

DESIGNED BY: XX_ DRAWN BY: XX_ CHECKED BY: XX_ DESIGN ENGINEER SBMWD ENGINEER

BENCHMARK: _____

ELEV.= XXXX.XX FT.

CITY OF SAN BERNARDINO
MUNICIPAL WATER DEPARTMENT

PROJECT TITLE
RIGHT-OF-WAY AND MONUMENTATION

DRAWING SCALES:
HORIZ: N/A VERT: N/A
C.O. NO.:
XXXX
DWG SV1
SHEET **5** OF **XX**

XX SUBMITTAL