



NOTES:

1. CONCRETE ENCASEMENT SHALL BE INSTALLED AS REQUIRED BY THE SPECIFICATIONS OR DIRECTED BY THE ENGINEER
2. CONCRETE SHALL BE CLASS 420-C-2000.



CONCRETE ENCASEMENT NO. 1

PIPE DIAM	DIMENSIONS	
	A	B
4"	4"	4"
6"	4"	4"
8"	4"	4"
10"	4"	4"
12"	4"	4"
15"	4"	4"
18"	5"	5"
21"	5"	5"
24"	6"	6"
27"	6"	7"
30"	6"	8"



CONCRETE ENCASEMENT NO. 2

N.T.S.

REVISION	DATE	CITY OF SAN BERNARDINO MUNICIPAL WATER DEPARTMENT		DRAWING NUMBER
		CONCRETE ENCASEMENT		SBMWD
				S.309
DRAWN BY: JRVS		APPROVED	DATE	07/03/2019
SUPERVISED: AC		WARREN HUANG, P.E. RCE 49208		